

THE PARISH OF ST. GEORGE'S WORCESTER

GAS SAFETY		Ref. No. 06
Hazards associated with this activity		
<p>Fire Explosion</p>	<p>Carbon monoxide poisoning</p>	
Control Measures		
<p>All gas appliances are checked and certified by a competent – Gas Safe registered- person on an annual basis.</p> <p>The area around the meter and incoming services is kept clear.</p> <p>The gas meter cupboard which is situated outside is kept locked at all times.</p> <p>All employees know what action to take when a gas leak is suspected.</p> <p>The gas supply isolators are readily identifiable and accessible and periodically operated (closed & reopened).</p> <p>Gas installations & appliances are installed only by externally approved contractor</p>	<p>Rooms with gas appliances are adequately ventilated.</p> <p>Flues are sited away from openable windows & doors to prevent flue gases from re-entering buildings</p> <p>All employees must not tamper with any gas appliance or supply. Suspected problems must be reported immediately to the parish office.</p>	
<p>Having reviewed the above in the context of the activity you are assessing, use the space below to record any actions that are needed for safety - (also state if OK & no action needed)</p>		<p>Responsibility & target date</p>
<p>Groups/people affected: Employees and volunteers</p>		
<p>Signature of person responsible for this activity confirming that this risk assessment has been carried out with the relevant people</p>	<p>Signed:</p> <p>Print: J STEVENSON</p>	<p>Date:</p> <p>JAN 2017</p>
<p>Approval by the Person in charge of area/Head of Department/Senior Manager (please indicate which)</p>	<p>Signed:</p> <p>Print: FATHER BRYAN</p>	<p>Date:</p> <p>JAN 2017</p>